



Cabinet shall be a minimum of 24" from the floor or ground to the bottom of the cabinet.

Minimum specifications listed below per LPC specifications and must also be in compliance with the National Electric Code.

<u>TYPE OF SERVICE</u>	<u>WIDTH</u>	<u>HEIGHT</u>	<u>DEPTH</u>
SINGLE PHASE, 120/208, 120/240	24"	24"	10"
SINGLE PHASE, 277/480, 240/240	30"	30"	10"
THREE PHASE, 120/208, 120/240, LESS THAN 1000 AMPS	24"	24"	10"
GREATER THAN 1000 AMPS	24"	24"	12"
THREE PHASE, 277/480, 240/480, LESS THAN 1000 AMPS	36"	36"	10"
GREATER THAN 1000 AMPS	36"	36"	12"



## CURRENT TRANSFORMER CABINET SPECIFICATIONS

REV: 3

MTR-10

SCALE: Not to Scale

POWER & COMMUNICATIONS

DATE: 5/13

DRAWN BY: RAWTMF

APPROVED: